

REQUEST FOR AGENDA PLACEMENT FORM

Submission Deadline - Tuesday, 12:00 PM before Court Dates

SUBMITTED BY: Joshua Green

TODAY'S DATE: 04/04/2022

DEPARTMENT: Facilities Management

SIGNATURE OF DEPARTMENT HEAD: _____



REQUESTED AGENDA DATE: 04/11/2022

SPECIFIC AGENDA WORDING:

Consideration to Approve Transformer Disconnect per Punchlist

Add Additional Disconnect per Electrical Engineer and to Approve the Change Order Amount of \$3, 802.42

Give County Judge the Authorization to Sign

COMMISSIONERS COURT

APR 11 2022

Approved

PERSON(S) TO PRESENT ITEM:

Joshua Green

SUPPORT MATERIAL: (Must enclose supporting documentation)

TIME: 3

(Anticipated number of minutes needed to discuss item)

ACTION ITEM: ✓

WORKSHOP:

CONSENT:

EXECUTIVE:

STAFF NOTICE:

COUNTY ATTORNEY:

IT DEPARTMENT:

AUDITOR: ✓

PURCHASING DEPARTMENT: ✓

PERSONNEL:

PUBLIC WORKS:

BUDGET COORDINATOR: ✓

OTHER:

This Section to be completed by County Judge's Office

ASSIGNED AGENDA DATE: _____

REQUEST RECEIVED BY COUNTY JUDGE'S OFFICE:

COURT MEMBER APPROVAL:

DATE:



13600 Heritage Parkway, Suite 150
 Fort Worth, TX 76177
 Ph: 817-926-4377
 Fax: 817-926-4387

PROPOSED CHANGE REQUEST

To: **Johnson County Courthouse**
 247 Elk Drive
 Burleson, TX 76028

Number: 13R
 Date: 3/24/22
 Job: 201226

Description: Transformer Disconnect

Description:		Price
1	125 Amp Transformer Disconnect per Punchlist	\$2,950.00
2	Supervision	\$600.00
	Contingency Amount	Subtotal: \$ 3,550.00
	Insurance	0.87% \$30.89
		Subtotal: \$3,580.89
	OH & Fee	5.00% \$179.04
		Subtotal: \$3,759.93
	Bond	1.13% \$42.49
	Change Order Amount	\$3,802.42

Approvals:

Johnson County
 Date: 4/11-22

Komatsu

Date: 24 Mar 2022

AUI
 Date: 3/24/2022

J. Sullivan

3/24/2022



Quotation

3200 Joyce Dr. Fort Worth, Texas 76116
 817-656-8455 trunnels@tmelectric.com

DATE December 9, 2021
 Quotation # CR #8 JCCH
 Customer ID AUI

ATTN: Jim Sullivan
 Project: Johnson County Subcourthouse Renovation
 Location: Burleson, Texas

CR #8

Quotation valid until: January 9, 2022
 Prepared by: Todd Runnels

Comments, special terms or special instructions: Change Request / Extra Lighting Dimming

Description	AMOUNT
Furnish and install 200 amp disconnect and 125 amp fuses for 45 KVA transformer secondary protection. The plans called for Panel P3 to be a main lug only panel.	
Exclusions:	
Any work not specifically listed above.	
Any sales tax.	
TOTAL	\$2,950.00

All work to be completed in a workmanlike manner according to standard practices.
 Any alteration or deviation from the above specifications involving extra costs will be done only upon written orders.
 All agreements contingent upon strikes, accidents or delays beyond our control. Client to carry all necessary insurance.
 Accepted: _____ Date: _____

THANK YOU FOR YOUR BUSINESS!