

MAY 09 2022

Approved

REQUEST FOR AGENDA PLACEMENT FORM

Submission Deadline - Tuesday, 12:00 PM before Court Dates

SUBMITTED BY: Jennifer VanderLaan **TODAY'S DATE: 05/03/2022**

DEPARTMENT: **Public Works**

SIGNATURE OF DEPARTMENT HEAD: _____

REQUESTED AGENDA DATE: **05/09/2022**

SPECIFIC AGENDA WORDING:

Review of Flood Study for 8700 E FM 917, by Half Associates, and Consideration of Recommendations.

PERSON(S) TO PRESENT ITEM: **Jennifer VanderLaan**

SUPPORT MATERIAL: (Must enclose supporting documentation)

TIME: 10 minutes **ACTION ITEM: X**

WORKSHOP _____

(Anticipated number of minutes needed to discuss item) **CONSENT:** _____

EXECUTIVE: _____

STAFF NOTICE:

COUNTY ATTORNEY: X **IT DEPARTMENT:** _____

AUDITOR: _____ **PURCHASING DEPARTMENT:** _____

PERSONNEL: _____ **PUBLIC WORKS: X** _____

BUDGET COORDINATOR: **OTHER:** _____

*****This Section to be Completed by County Judge's Office*****

ASSIGNED AGENDA DATE: _____

REQUEST RECEIVED BY COUNTY JUDGE'S OFFICE _____

COURT MEMBER APPROVAL _____ Date _____

From: Dueck, Randy <rDueck@Halff.com>
Sent: Thursday, April 28, 2022 8:15 AM
To: Jennifer Vanderlaan; Bill Moore; Mike White
Cc: Pylant, Ben
Subject: FM 917 - Orr Expansion Flood Study Approval Recommendation
Attachments: OrrExpansion_Review3.pdf

Follow Up Flag: Follow up
Flag Status: Flagged

Jennifer,

We have completed our review of the flood study for FM 917 provided by MMA Inc., received by Halff Associates Inc on April 18, 2022. At this time all our comments have been addressed. See the attached letter addressed to Commissioner Mike White for our recommendation.

We note the following future actions were agreed to during the flood study review process:

1. Construction plans will include a drainage easement dedication which contains the proposed 100-year floodplain depicted in the flood study.
2. Upon completion of the grading in the floodplain, a FEMA LOMR application will be submitted. The application must be an MT-2 submittal including a hydraulic analysis. An MT-1 submittal based solely on fill is not acceptable.

Please let us know if you want to discuss anything,

Randy Dueck, PE, CFM
Project Manager
Halff Associates, Inc.

O: (817) 764-7481



We improve lives and communities
by turning ideas into reality.

Halff.com | [LinkedIn](#) | [Facebook](#) | [Twitter](#) | [Instagram](#) | [YouTube](#)



April 28, 2022
AVO 32083

Mike White, Commissioner
Johnson County, Precinct 3
4300 E. FM 4
Cleburne, TX 76031

Re: Orr Expansion – 8700 FM 917 – Flood Study Review #3

Dear Mr. White:

The revised flood study by MMA, Inc. for the referenced project was received by Halff Associates, Inc. on April 18, 2022. At this time, all our comments have been addressed and we recommend approval of the flood study.

If you have any questions or need additional information, please do not hesitate to call me at (817) 764-7481, or Ben Pylant at (817) 764-7488.

Sincerely,
HALFF ASSOCIATES, INC.
TBPE Firm No. 312

A handwritten signature in blue ink, appearing to read "Randy Dueck", is written over a faint, larger version of the same signature.

Randy Dueck, P.E., CFM